

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:127 Page 1 of 1

CATEGORY: Misc Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Optional detector accessories:

5956	Remote Annunciator
6262-001	Key Switch
6254-003	Fire Alarm Relay
6254-001	Fire Alarm Power Supply
6256-200	Fire Alarm /Indicator/Testing Station
SIGA-LED	Remote LED Alarm Indicator
SIGA-DTS	Remote Test Station
SIGA-DG	Smoke Detector Guard

All prefixes may be followed by a alpha character between A and Z except C to classify a specific market.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as optional accessories. Intended for use with separately listed compatible detectors. Model SIGA-DG is intended for use only with Models SIGA-IPHS (CSFM Listing No. 7258-1591:123) and SIGA-PS (CSFM Listing No. 7272-1591:126) smoke detectors.

NOTE: Formerly 7300-1388:191

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JANUARY 16, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager